

ACT GOVERNMENT
Asbestos Testing Laboratory
Airborne Fibre Monitoring Results

NATA Registration No: 3210



This laboratory is registered by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of registration.

Authorisation No: QCZDF14
Performed at:
Removal Contractor: GARDNER-PERROTT

Date: 27-Nov-92

Test Method: Filters examined in accordance with 1988 NOHSC Guidance Note on the Membrane Filter Method (as outlined in the Laboratory manual).

sampling Procedure: Paraoccupational. Sampling procedure is not covered by the terms of registration.

Work in Progress: Fine Cleaning

Slide	Location	Time On	Time Off	Coll by	Anal by	No of Fibres	No Flds	Fibres/mL*
ZDF088	Change Area	656	1157	OB	OB	1.0	100	< .01
ZDF089	Clean Shower	656	1157	OB	OB	1.5	100	< .01
ZDF090	Decon Laundry	657	1159	OB	OB	1.0	100	< .01
ZDF091	Neg Air 3	700	1153	OB	OB	1.0	100	Pass
ZDF092	Lunchroom	658	1151	OB	OB	2.5	100	< .01
ZDF093	Bathroom	702	1155	OB	OB	2.5	100	< .01
ZDF094	Hall/Entry	702	1155	OB	OB	2.0	100	< .01

* Volume measurement not covered by terms of registration

Report Authorised by: Danny Walters *Danny Walters* Date: 27-Nov-92

ACT GOVERNMENT
Asbestos Testing Laboratory
Airborne Fibre Monitoring Results

NATA Registratrion No: 3210



This laboratory is registered by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of registration.

Authorisation No: QCZDF13
Performed at:
Removal Contractor: GARDNER-PERROTT

Date: 26-Nov-92

Test Method: Filters examined in accordance with 1988 NOHSC Guidance Note on the Membrane Filter Method (as outlined in the Laboratory manual).

Sampling Procedure: Paraoccupational. Sampling procedure is not covered by the terms of registration.

Work in Progress: Fine Cleaning

Slide	Location	Time On	Time Off	Coll by	Anal by	No of Fibres	No Flds	Fibres/mL*
ZDF081	Change Area	708	1201	OB	OB	2.0	100	< .01
ZDF082	Clean Shower	708	1201	OB	OB	0.0	0	CANCELLED *r
ZDF083	Decon Laundry	709	1158	OB	OB	2.0	100	< .01
ZDF084	Neg Air 2	713	1154	OB	OB	0.0	100	Pass
ZDF085	Lunchroom	709	1152	OB	OB	5.0	100	< .01
ZDF086	Bedroom 4	714	1156	OB	OB	1.5	100	< .01
ZDF087	Ensuite	714	1157	OB	OB	2.0	100	< .01

* Volume measurement not covered by terms of registration

Report Authorised by: Danny Walters Danny Walters Date: 26-Nov-92

**ACT GOVERNMENT
Asbestos Testing Laboratory
Airborne Fibre Monitoring Results**

NATA Registration No: 3210



This laboratory is registered by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of registration.

Authorisation No: QCZDF12

Performed at:

Removal Contractor: GARDNER-PERROTT

Date: 25-Nov-92

Test Method: Filters examined in accordance with 1988 NOHSC Guidance Note on the Membrane Filter Method (as outlined in the Laboratory manual).

Sampling Procedure: Paraoccupational. Sampling procedure is not covered by the terms of registration.

Work in Progress: Decon clearance

Slide	Location	Time On	Time Off	Coll. by	Anal. by	No of Fibres	No Flds	Fibres/mL*
ZDF071	Change Area	659	845	KTV	KTV	2.0	100	< .03
ZDF072	Clean Shower	659	845	KTV	KTV	3.0	100	< .02

Work in Progress: Fine Cleaning

Slide	Location	Time On	Time Off	Coll. by	Anal. by	No of Fibres	No Flds	Fibres/mL*
ZDF073	Decon Laundry	700	1201	OB	OB	3.0	100	< .01
ZDF074	Neg Air 1	703	1157	OB	OB	0.0	100	Pass
ZDF075	Lunchroom	701	1154	OB	OB	3.5	100	< .01
ZDF076	Laundry	706	1159	OB	OB	1.0	100	< .01
ZDF077	Office	706	1159	OB	OB	1.0	100	< .01
ZDF078	Yard	704	1159	OB	OB	0.0	100	< .01
ZDF079	Change Area	846	1202	OB	OB	1.0	100	< .01
ZDF080	Clean Shower	846	1202	OB	OB	1.0	100	< .01

* Volume measurement not covered by terms of registration

Report Authorised by: Danny Walters *Danny Walters* Date: 25-Nov-92

**ACT GOVERNMENT
Asbestos Testing Laboratory
Airborne Fibre Monitoring Results**

NATA Registration No: 3210



This laboratory is registered by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of registration.

Authorisation No: QCZDF10
 Performed at:
 Removal Contractor: GARDNER-PERROTT

Date: 20-Nov-92


Test Method: Filters examined in accordance with 1988 NOHSC Guidance Note on the Membrane Filter Method (as outlined in the Laboratory manual).

Sampling Procedure: Paraoccupational. Sampling procedure is not covered by the terms of registration.

Work in Progress: Fine Cleaning

Slide	Location	Time On	Time Off	Coll by	Anal by	No of Fibres	No Flds	Fibres/mL*
ZDF058	Change Area	648	1154	OB	OB	2.0	100 <	.01
ZDF059	Clean Shower	648	1154	OB	OB	1.0	100 <	.01
ZDF060	Decon Laundry	649	1146	OB	OB	3.0	100 <	.01
ZDF061	Lunchroom	643	1142	OB	OB	2.5	100 <	.01
ZDF062	Bathroom	646	1144	OB	OB	1.0	100 <	.01
ZDF063	Hall/Entry	646	1143	OB	OB	1.5	100 <	.01

* Volume measurement not covered by terms of registration

Report Authorised by: Danny Walters  Date: 20-Nov-92

ACT GOVERNMENT
Asbestos Testing Laboratory
Airborne Fibre Monitoring Results

NATA Registration No: 3210



This laboratory is registered by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of registration.

Authorisation No: QCZDF09

Performed at:

Removal Contractor: GARDNER-PERROTT

Date: 19-Nov-92

Test Method: Filters examined in accordance with 1988 NOHSC Guidance Note on the Membrane Filter Method (as outlined in the Laboratory manual).

Sampling Procedure: Paraoccupational. Sampling procedure is not covered by the terms of registration.

Work in Progress: Bulk removal & Bag-out

Slide	Location	Time On	Time Off	Coll by	Anal by	No of Fibres	No Flds	Fibres/mL*
ZDF047	Change Area	644	1202	OB	OB	2.0	100	< .01
ZDF048	Clean Shower	644	1202	OB	OB	2.0	100	< .01
ZDF049	Decon Laundry	645	1203	OB	OB	3.0	100	< .01
ZDF050	Neg Air 3	634	1156	OB	OB	0.0	100	Pass
ZDF051	Lunchroom	642	1154	OB	OB	4.0	100	< .01
ZDF052	Bedroom 4	640	1158	OB	OB	2.0	100	< .01
ZDF053	Ensuite	640	1158	OB	OB	0.0	100	< .01
ZDF054	Yard (remonitor)	636	1159	OB	OB	0.0	100	< .01
ZDF055	Bulk Ext.No.3(inlet)	649	1153	OB	OB	0.0	100	< .01
ZDF056	Bulk Ext.No.3(outlet)	649	1153	OB	OB	0.0	100	< .01
ZDF057	Bag Out (adj.decon)	646	1203	OB	OB	0.0	100	< .01

* Volume measurement not covered by terms of registration

Report Authorised by: Danny Walters

Date: 19-Nov-92

**ACT GOVERNMENT
Asbestos Testing Laboratory
Airborne Fibre Monitoring Results**

NATA Registration No: 3210



This laboratory is registered by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of registration.

Authorisation No: QCZDF08

Performed at: _____

Removal Contractor: GARDNER-PERROTT

Date: 18-Nov-92

Test Method: Filters examined in accordance with 1988 NOHSC Guidance Note on the Membrane Filter Method (as outlined in the Laboratory manual).

Sampling Procedure: Paraoccupational. Sampling procedure is not covered by the terms of registration.

Work in Progress: Tile cleaning & Bulk removal

Slide	Location	Time On	Time Off	Coll by	Anal by	No of Fibres	No Flds	Fibres/mL*
ZDF035	Change Area	646	1206	OB	OB	2.0	100	< .01
ZDF036	Clean Shower	646	1206	OB	OB	1.5	100	< .01
ZDF037	Decon Laundry	647	1206	OB	OB	.5	100	< .01
ZDF038	Neg Air 2	639	1204	OB	OB	0.0	100	Pass
ZDF039	Lunchroom	644	1153	OB	OB	2.0	100	< .01
ZDF040	Bulk Ext.No.4 (inlet)	635	1152	OB	OB	0.0	100	< .01
ZDF041	Bulk Ext.No.4 (outlet)	635		OB	OB	0.0	0	CANCELLED *p
ZDF042	Kitchen	652	1158	OB	OB	1.0	100	< .01
ZDF043	Office	652	1158	OB	OB	1.5	100	< .01
ZDF044	Yard	637		OB	OB	0.0	0	CANCELLED *p
Z. 045	Tile bay (rear)	640	1203	OB	OB	1.0	100	< .01
ZDF046	Bedroom 2 (remonitor)	652	1158	OB	OB	1.5	100	< .01

* Volume measurement not covered by terms of registration

Report Authorised by: Danny Walters

Danny Walters

Date: 18-Nov-92

**ACT GOVERNMENT
Asbestos Testing Laboratory
Airborne Fibre Monitoring Results**

NATA Registration No: 3210



This laboratory is registered by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of registration.

Authorisation No: QCZDF07

Performed at:

Removal Contractor: GARDNER-PERROTT

Date: 17-Nov-92

Test Method: Filters examined in accordance with 1988 NOHSC Guidance Note on the Membrane Filter Method (as outlined in the Laboratory manual).

Sampling Procedure: Paraoccupational. Sampling procedure is not covered by the terms of registration.

Work in Progress: Tile cleaning

Slide	Location	Time On	Time Off	Coll by	Anal by	No of Fibres	No Flds	Fibres/mL*
ZDF024	Change Area	636	1205	JS	JS	1.5	100	< .01
ZDF025	Clean Shower	636	1206	JS	JS	1.0	100	< .01
ZDF026	Decon Laundry	637	1155	JS	JS	1.0	100	< .01
ZDF027	Neg Air 1	649	1153	JS	JS	0.0	100	Pass
ZDF028	Lunchroom	634	1154	JS	JS	5.0	100	< .01
ZDF029	Bedroom 2	645		JS	JS	0.0	0	CANCELLED *p
ZDF030	Living/Dining	645	1156	JS	JS	0.0	100	< .01
ZDF031	Laundry	646	1157	JS	JS	1.0	100	< .01
ZDF032	Kitchen/Family	646	1158	JS	JS	0.0	100	< .01
ZDF033	Tile bay (front)	640	1159	JS	JS	1.5	100	< .01
Z 034	Tile bay (back)	650	1152	JS	JS	2.0	100	< .01

* Volume measurement not covered by terms of registration

Report Authorised by: Bill Moore

Bill Moore Date: 17-Nov-92

**ACT GOVERNMENT
Asbestos Testing Laboratory
Airborne Fibre Monitoring Results**

NATA Registration No: 3210



This laboratory is registered by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of registration.

Authorisation No: QCZDF06

Performed at:

Removal Contractor: GARDNER-PERROTT

Date: 16-Nov-92

Test Method: Filters examined in accordance with 1988 NOHSC Guidance Note on the Membrane Filter Method (as outlined in the Laboratory manual)..

Sampling Procedure: Paraoccupational. Sampling procedure is not covered by the terms of registration.

Work in Progress: Tile cleaning

Slide	Location	Time On	Time Off	Coll by	Anal by	No of Fibres	No Flds	Fibres/mL*	
ZDF013	Bedroom 1	645	1331	JS	JS	2.5	100	< .01	
ZDF014	Toilet	645	1332	JS	JS	1.5	100	< .01	
ZDF015	Kitchen/Family	644		JS	JS	0.0	0	CANCELLED	*p
ZDF016	Change Area	640	1330	JS	JS	3.0	100	< .01	
ZDF017	Clean Shower	640	1330	JS	JS	2.0	100	< .01	
ZDF018	Neg Air 1	653	1334	JS	JS	1.0	100	Pass	
ZDF019	Neg Air 2	653	1334	JS	JS	1.0	100	Pass	
ZDF020	Neg Air 3	653	1335	JS	JS	1.0	100	Pass	
ZDF021	Neg Air 4	653	1335	JS	JS	0.0	100	Pass	
ZDF022	Tile bay(rear)	655	1337	JS	JS	1.5	100	< .01	
ZDF023	Tile bay(front)	658		JS	JS	0.0	0	CANCELLED	*p

* Volume measurement not covered by terms of registration

Report Authorised by: Bill Moore *W Moore* Date: 16-Nov-92

ACT GOVERNMENT
Asbestos Testing Laboratory
Airborne Fibre Monitoring Results

NATA Registration No: 3210

This laboratory is registered by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of registration.

Authorisation No: QCZDF05
Performed at:
Removal Contractor: GARDNER-PERROTT



Date: 13-Nov-92

Test Method: Filters examined in accordance with 1988 NOHSC Guidance Note on the Membrane Filter Method (as outlined in the Laboratory manual).

Sampling Procedure: Paraoccupational. Sampling procedure is not covered by the terms of registration.

Work in Progress: in house clearance

Slide	Location	Time On	Time Off	Coll by	Anal by	No of Fibres	No Flds	Fibres/mL*
ZDF012	playroom	1556	1658	RoS	DM	2.0	100	< .02

* Volume measurement not covered by terms of registration

Report Authorised by: Danny Walters *Danny Walters* Date: 13-Nov-92

ACT GOVERNMENT
Asbestos Testing Laboratory
Airborne Fibre Monitoring Results

NATA Registration No: 3210

This laboratory is registered by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of registration.

Authorisation No: QCZDF04
Performed at:
Removal Contractor: GARDNER-PERROTT



Date: 11-Nov-92

Test Method: Filters examined in accordance with 1988 NOHSC Guidance Note on the Membrane Filter Method (as outlined in the Laboratory manual).

Sampling Procedure: Paraoccupational. Sampling procedure is not covered by the terms of registration.

Work in Progress: set up

Slide	Location	Time On	Time Off	Coll by	Anal by	No of Fibres	No Flds	Fibres/mL*
ZDF010	bed 3	749	1355	DM	DM	3.0	100 <	.01
ZDF011	office	749	1356	DM	DM	1.5	100 <	.01

* Volume measurement not covered by terms of registration

Report Authorised by: Danny Walters *Danny Walters* Date: 11-Nov-92

ACT GOVERNMENT
Asbestos Testing Laboratory
Airborne Fibre Monitoring Results

NATA Registration No: 3210



This laboratory is registered by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of registration.

Authorisation No: QCZDF03

Performed at:

Removal Contractor: *GP.*

Date: 10-Nov-92

Test Method: Filters examined in accordance with 1988 NOHSC Guidance Note on the Membrane Filter Method (as outlined in the Laboratory manual).

Sampling Procedure: Paraoccupational. Sampling procedure is not covered by the terms of registration.

Work in Progress: Set-up

Slide	Location	Time On	Time Off	Coll by	Anal by	No of Fibres	No Flds	Fibres/mL*
ZDF008	Laundry	832	1345	JS	JS	0.0	100	< .01
ZDF009	Bedroom 1	833	1346	JS	JS	1.0	100	< .01

* Volume measurement not covered by terms of registration

Report Authorised by: Bill Moore

Date: 10-Nov-92

ACT GOVERNMENT
Asbestos Testing Laboratory
Airborne Fibre Monitoring Results

NATA Registration No: 3210



This laboratory is registered by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of registration.

Authorisation No: QCZDF02

Performed at:

Removal Contractor:

Date: 30-Oct-92

Test Method: Filters examined in accordance with 1988 NOHSC Guidance Note on the Membrane Filter Method (as outlined in the Laboratory manual).

Sampling Procedure: Paraoccupational. Sampling procedure is not covered by the terms of registration.

Work in Progress: In house clearance

Slide	Location	Time On	Time Off	Coll by	Anal by	No of Fibres	No Flds	Fibres/mL*
DF004	Kitchen	1054	1159	RoS	RoS	4.0	100 <	.02
DF005	Dining Room	1054	1159	RoS	RoS	2.0	100 <	.02
DF006	Bedroom 4	1055	1200	RoS	RoS	4.5	100 <	.02
DF007	Bedroom 1	1056	1201	RoS	RoS	1.0	100 <	.02

Volume measurement not covered by terms of registration

Report Authorised by: Danny Walters

Date: 30-Oct-92

ACT GOVERNMENT
Asbestos Testing Laboratory
Airborne Fibre Monitoring Results

NATA Registration No: 3210



This laboratory is registered by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of registration.

Authorisation No: QCZDF01
Performed at:
Removal Contractor:

Date: 19-Oct-92

Test Method: Filters examined in accordance with 1988 NOHSC Guidance Note on the Membrane Filter Method (as outlined in the Laboratory manual).

sampling Procedure: Paraoccupational. Sampling procedure is not covered by the terms of registration.

Work in Progress: Backgrounds

Slide	Location	Time On	Time Off	Coll by	Anal by	No of Fibres	No Flds	Fibres/mL*
ZDF001	kitchen	739	1215	JG	JG	6.0	100	< .01
ZDF002	lounge room	738	1215	JG	JG	9.0	100	< .01
ZDF003	main bedroom	740	1215	JG	JG	8.5	100	< .01

* Volume measurement not covered by terms of registration

Report Authorised by: Danny Walters *Danny Walters* Date: 19-Oct-92